

FIRE HYDRANT LOCATION IN CUT OR FILL

N.T.S.



NOTE: VALVE TO BE PLACED ON THE MAIN FOR NEW CONSTRUCTION. AVOID PLACING THE VALVE IN CURB & GUTTER FOR RETROFIT PROJECTS.

FIRE HYDRANT ASSEMBLY

N.T.S.



TYPICAL FIRE HYDRANT LOCATION



FIRE HYDRANT GUARD POSTS

FIRE HYDRANTS SHALL BE FOR ORDINARY WATER WORKS SERVICES AS DESCRIBED IN AWWA C-502-54.

A. EACH HYDRANT SHALL HAVE 5" MVO WITH "O" RING SEALS, A BREAKAWAY FLANGE, A 1 1/4" OPERATING NUT AND NOZZLE CAP NUTS THAT OPEN COUNTER CLOCKWISE. GASKETS AND NOZZLE CAP SHALL BE INCLUDED.

B. SHUT-OFF TYPE: COMPRESSION OR GATE.

C. INLET CONNECTION: 6" MECHANICAL JOINT (125#) INLET.

D. CONNECTION PORTS:
TWO (2)-2 1/2" I.D. HOSE NOZZLE PORTS WITH N.S.T. THREADS.
ONE (1)-4" I.D. PUMPER OR STEAMER NOZZLE WITH P.C.T. THREADS AT SIX (6) THREADS PER INCH WITH AN O.D. OF 4.828" AND A THREAD BEVEL OF 60. THIS SHALL ALSO HAVE A STORTZ FITTING AS INDICATED ON THE DETAIL.
STORTZ FITTING-4" STORTZ TYPE ADAPTER WITH CAP AND CHAIN AND PYROLITE RIGID FEMALE CONNECTOR WITH SET SCREW. THE THREAD CUT ON THE FITTING SHALL MATCH EXISTING STANDARDS.
THE STORTS FITTING SHALL NOT EXTEND PAST THE BACK OF THE SIDEWALK AND SHALL BE ORIENTED TO FACE THE WATER MAIN, OR AS DIRECTED BY THE CITY ENGINEER.

E. DEPTH OF BURY SHALL BE 4 1/2" OR 5 1/2" DEPENDING ON THE CONDITIONS.

F. ALL NOZZLES SHALL CONFORM TO CURRENT CITY OF WENATCHEE HYDRANTS.

G. HYDRANT SHALL BE PAINTED YELLOW IN ACCORDANCE WITH AWWA C-502-54, SECTION 6.

H. APPROVED MANUFACTURERS: MUELLER, M & H, CLOW F2500, OR KENNEDY GUARDIAN K-81. ONLY THESE BRANDS WILL BE ACCEPTED.

I. ALL HYDRANTS SHALL BE EQUIPPED WITH TRAFFIC BREAKING FLANGES.

J. ALL INSTALLATIONS WILL HAVE A RESILIENT SEAT AUXILIARY VALVE.

K. ALL HYDRANTS SHALL HAVE MEGALUG RESTRAINED JOINTS.

L. THE MINIMUM DISTANCE FROM THE BOTTOM OF THE LOWEST PORT TO FINISHED GRADE SHALL BE 18". THE DISTANCE FROM FINISHED GRADE TO THE BREAKING FLANGE SHALL BE A MINIMUM OF 2" AND A MAXIMUM OF 4".

M. HYDRANT GUARD POST SHALL BE 8" DIAMETER x 6' LONG PRECAST CONCRETE POST EQUAL TO FOG-TITE METER SEAL CO,. PAINT WITH TWO COATS OSHA SAFETY YELLOW ENAMEL.

STANDARD DETAIL
FIRE HYDRANT
SPECIFICATIONS AND DETAILS

City of Wenatchee

REVISIONS	
DATE	01/22
INITIAL	AJS

DATE DRAWN 3/23/2015	CHECKED DMN	DATE APPROVED	STANDARD SPECIFICATIONS 7-09 WATER MAINS 7-12 VALVES 7-14 HYDRANTS
SCALE: AS SHOWN N.A.	DRAWN RDH		
DESIGNED DMN	APPROVED BY		

DETAIL NO.
W-100

PAGE
1 OF 1





NOTES:

1. AN APPROVED BACK FLOW ASSEMBLY SHALL BE INSTALLED BETWEEN THE NEW AND EXISTING WATERLINES DURING DISINFECTION AND FLUSHING OF NEW WATER MAIN.
2. THE BACK FLOW PREVENTION ASSEMBLY AND SUPPLY HOSE MUST BE DISCONNECTED DURING HYDROSTATIC PRESSURE TESTING OF THE NEW MAIN.
3. THE NEW WATER MAIN SHALL BE CONNECTED TO THE EXISTING SYSTEM ONLY AFTER THE NEW MAIN IS FLUSHED, DISINFECTED AND SATISFACTORY BACTERIOLOGICAL SAMPLE RESULTS ARE OBTAINED.
4. THE INTERIORS OF ALL PIPES AND FITTINGS TO BE USED IN FINAL CONNECTION MUST BE SWABBED OR SPRAYED WITH A 1% AVAILABLE CHLORINE SOLUTION.
5. 2" HYDRANT METER SHALL BE OBTAINED FROM THE CITY OF WENATCHEE PUBLIC WORKS DEPARTMENT OR CHELAN COUNTY PUD HYDRANT VALVE MAY BE USED UNDER SOME CIRCUMSTANCES.
6. DECHLORINATOR REQUIRED, CONTRACTOR MAY FLUSH TO SEWER OR STORM AFTER USING DECHLORINATOR. NOTIFY WENATCHEE WASTE WATER TREATMENT PLANT PRIOR TO FLUSH AIR GAP AT DISCHARGE.

STANDARD DETAIL
FILLING NEW WATER MAINS

City of Wenatchee

REVISIONS	
DATE	INITIAL
01/22	AJS

DATE DRAWN 11/04/2020	CHECKED	DATE APPROVED	STANDARD SPECIFICATIONS
SCALE: AS SHOWN	DRAWN: CAW	APPROVED BY	
	DESIGNED		

DETAIL NO.
W–110



PARALLEL CONSTRUCTION

WATER MAIN STANDARD PIPE MATERIAL

AWWA STANDARD			
TYPE OF PIPE	PIPE	JOINT	FITTINGS
DUCTILE IRON	C 1.52	C 111	C 110
CONCRETE CYLINDER	C 303		

NOTES:

1. HORIZONTAL SEPARATION (PARALLEL) – A MINIMUM HORIZONTAL SEPARATION OF TEN (10) FEET BETWEEN GRAVITY SANITARY SEWERS AND ANY POTABLE WATER LINES SHALL BE MAINTAINED, WHENEVER POSSIBLE. THE DISTANCE SHALL BE MEASURED FROM EDGE TO EDGE.

2. UNUSUAL CONDITIONS (PARALLEL) – WHEN LOCAL CONDITIONS PREVENT A HORIZONTAL SEPARATION AS DESCRIBED ABOVE, A GRAVITY SEWER LINE MAY BE LAID CLOSER THAN TEN (10) FEET TO A WATER LINE PROVIDED:

   A)IT IS LAID IN A SEPARATE TRENCH; OR IT IS LAID IN THE SAME TRENCH WITH THE WATER LINE THAT IS LOCATED AT ONE SIDE ON A BENCH OF UNDISTURBED EARTH; AND

   B)IN EITHER CASE, THE ELEVATION OF THE CROWN OF THE GRAVITY SEWER MUST BE AT LEAST 18 INCHES BELOW THE INVERT OF THE WATER LINE. WHEN THIS VERTICAL SEPARATION CANNOT BE OBTAINED, THE GRAVITY SEWER SHALL BE CONSTRUCTED OF MATERIALS AND JOINTS THAT ARE 8 EQUIVALENT TO WATER MAIN STANDARDS OF CONSTRUCTION AND SHALL BE PRESSURE TESTED TO ASSURE WATER TIGHTNESS PRIOR TO BACKFILLING.

3. VERTICAL SEPARATION (PERPENDICULAR) – SEWER LINES CROSSING WATER LINES SHALL BE LAID BELOW THE WATER LINES TO PROVIDE A SEPARATION OF AT LEAST 18 INCHES BETWEEN THE INVERT OF THE WATER LINE AND THE CROWN OF THE SEWER LINE, WHENEVER POSSIBLE.

4. UNUSUAL CONDITIONS (PERPENDICULAR) – WHEN LOCAL CONDITIONS PREVENT A VERTICAL SEPARATION AS DESCRIBED ABOVE, THE FOLLOWING CONSTRUCTION SHALL BE USED:

   A)GRAVITY SEWERS PASSING OVER OR UNDER WATER LINES SHALL BE:
   I. CONSTRUCTED OF MATERIAL DESCRIBED ON THIS PAGE. THE ONE SEGMENT OF THE MAXIMUM STANDARD LENGTH OF PIPE (BUT NO LESS THAN 18 FEET LONG) SHALL BE USED WITH THE PIPES CENTERED TO MAXIMIZE JOINT SEPARATION; OR
   II. CONSTRUCTED OF STANDARD GRAVITY SEWER MATERIAL ENCASED IN CONCRETE OR IN A 1/4" THICK CONTINUOUS STEEL CASING WITH ALL VOIDS PRESSURE–GROUTED WITH SAND–CEMENT GROUT.
   III. THE LENGTH OF THE SEWER PIPE, IN BOTH I. AND II. ABOVE, SHALL BE CENTERED AT THE POINT OF CROSSING SO THAT THE JOINTS WILL BE EQUIDISTANT AND AS FAR AS POSSIBLE FROM THE WATER LINE. THE SEWER PIPE SHALL BE THE LONGEST STANDARD LENGTH AVAILABLE FROM THE MANUFACTURER.

   B)WATER LINES PASSING UNDER GRAVITY SEWERS, IN ADDITION, SHALL BE PROTECTED BY PROVIDING:
   I. A VERTICAL SEPARATION OF AT LEAST 18 INCHES BETWEEN THE INVERT OF THE SEWER AND THE CROWN OF THE WATER LINE;
   II. ADEQUATE STRUCTURAL SUPPORT FOR THE SEWERS TO PREVENT EXCESSIVE DEFLECTION OF JOINTS AND SETTLING ON AND BREAKING OF THE WATER LINES; AND
   III. THE LENGTH OF THE SEWER PIPE SHALL BE CENTERED AT THE POINT OF CROSSING SO THAT THE JOINTS WILL BE EQUIDISTANT AND AS FAR AS POSSIBLE FROM THE WATER LINE. THE SEWER PIPE SHALL BE THE LONGEST STANDARD LENGTH AVAILABLE FROM THE MANUFACTURER.

   C)PRESSURE SEWERS SHALL ONLY BE CONSTRUCTED UNDER WATER LINES WITH DUCTILE IRON PIPE OR STANDARD SEWER PIPE IN A STEEL CASING FOR A DISTANCE OF AT LEAST TEN (10) FEET ON EACH SIDE OF THE CROSSING.

STANDARD DETAIL
WATER AND SEWER
SPACING & CLEARANCE

City of Wenatchee

REVISIONS: DATE 01/22 INITIAL AJS

DATE DRAWN 12/04/2020 | CHECKED | DATE APPROVED

SCALE: AS SHOWN | DRAWN CAW | DESIGNED | APPROVED BY

STANDARD SPECIFICATIONS

DETAIL NO.
W–120

PAGE
1 OF 1



STANDARD DETAIL
CARRIER PIPE

KEY NOTES:

1. CARRIER PIPE SHALL BE USED AS REQUIRED WITHIN CITY RIGHT–OF–WAY.
2. ALL IRRIGATION PIPE LOCATED WITHIN CITY RIGHT–OF–WAY SHALL BE PVC C900 OR APPROVED EQUAL
3. ALL JOINTS THROUGHOUT CASING SHALL BE RESTRAINED WITH FIELD LOC INTERNAL RESTRAINTS OR APPROVED EQUAL.
4. RESTRAIN CARRIER PIPE ONE JOINT BEYOND END SEALS.
5. MANUFACTURED CASING SPACER INTERVAL PER MANUFACTURER'S SPECIFICATIONS BUT NOT MORE THAN 10–FEET. MINIMUM 3 SPACERS PER PIPE LENGTH.
6. CASING SHALL BE WELDED STEEL OR DUCTILE IRON FOR INSTALLATIONS LESS THAN 3–FEET BELOW ROAD GRADE. CPE MAY BE SUBSTITUTED FOR AREAS OUTSIDE OF PAVED ROADWAY.
7. CASING PIPE LENGTHS SHALL BE OF THE LONGEST AVAILABLE LENGTH OF PIPE FROM MANUFACTURER
8. NON–WELDED STEEL CASING SHALL BE EXTERNALLY RESTRAINED AT ALL JOINTS.
9. 3M MARKER BALL TO BE PLACED DIRECTLY ABOVE JOINT RESTRAINT AT END OF PIPE.
10. DETECTABLE MARKER TAPE TO BE INSTALLED 12–INCHES TO 14–INCHES ABOVE PIPE CASING. COLOR SHOULD BE ACCORDING TO APWA UNIFORM COLOR CODE FOR MARKING UNDERGROUND UTILITIES. DETECTABLE MARKING TAPE SHALL CONSIST OF INERT POLYETHYLENE PLASTIC THAT IS IMPERVIOUS TO ALL KNOWN ALKALIS, ACIDS, CHEMICAL REAGENTS, AND SOLVENTS LIKELY TO BE ENCOUNTERED IN THE SOIL, WITH A METALLIC FOIL CORE TO PROVIDE FOR THE MOST POSITIVE DETECTION AND PIPELINE LOCATION. DETECTABLE MARKING TAPE SHALL BE NO LESS THAN 2–INCHES WIDE, TYPE OF BURIED UTILITY SHOULD BE CLEARLY MARKED CONTINUOUSLY ALONG THE LENGTH OF THE RIBBON WITH MINIMUM 1–1/2 INCH LETTERS IN THE FOLLOWING FORMAT: "CAUTION BURIED (UTILITY TYPE) LINE"



CASING SPACERS DETAIL
NTS



NON WELDED JOINT DETAIL
NTS



SPACER DISTANCE FROM BELL DETAIL
NTS

City of Wenatchee

REVISIONS	DATE	INITIAL
	12/20/2017	JBV
	10/27/2020	CAW
	01/01/2022	AJS

DATE DRAWN 2/21/2006	CHECKED SK	DATE APPROVED	STANDARD SPECIFICATIONS
SCALE: AS SHOWN	DRAWN JB	APPROVED BY	
	DESIGNED		

DETAIL NO.
W–150

PAGE
1 OF 1

NOTES:

1. COVER SHALL NOT EXTEND MORE THAN 2" ABOVE GRADE WHEN VAULT IS NOT IN TRAFFIC AREA.
2. SLOPE PAVEMENT AWAY FROM COVER.
3. VAULT LID SHALL BE OF ADEQUATE HEIGHT TO PROVIDE MIN. 6" CLEARANCE TO O, S & Y VALVE WHEN VALVE IS FULLY OPEN.
4. 5/8" BY-PASS METER SHALL BE SENSUS SR II OR NEPTUNE T-10.
5. VAULTS SHALL BE AS MANUFACTURED BY UTILITY VAULT OR APPROVED EQUAL AND SHALL BE STRUCTURALLY DESIGNED FOR THE PROPOSED INSTALLATION.
6. BACK-FLOW VALVE AND ASSEMBLY MUST APPEAR ON CURRENT DEPT. OF HEALTH'S APPROVED VALVE LISTING.
7. ASSEMBLY SHALL BE MAINTAINED BY OWNER WITH A TEST DONE UPON INSTALLATION AND ANNUALLY THEREAFTER BY A CERTIFIED BACK-FLOW ASSEMBLY TESTER (BAT.) A COPY OF EACH ANNUAL TEST REPORT MUST BE SENT TO THE CITY OF WENATCHEE.
8. WATER MAIN SHALL NOT BE PLACED IN SERVICE UNTIL AFTER DOUBLE CHECK DETECTOR ASSEMBLY IS INSPECTED. TESTED AND APPROVED BY CITY REPRESENTATIVE.
9. RESTRAIN CHECK DETECTOR WITH MEGA-LUGS. RESTRAINED JOINT PIPE, OR SHACKLE RODS BACK TO WATER MAIN AS REQUIRED.



PLAN

SHOWN WITHOUT FIRE DEPARTMENT CONNECTION.
WHEN FDC IS AT ANOTHER LOCATION



PLAN

THIS DCDA VAULT SERVES A SINGLE BUILDING AND
THE VAULT IS LOCATED ADJACENT TO THE RIGHT
OF WAY WHERE A FIRE HYDRANT IS NEARBY.



SECTION



SECTION

STANDARD DETAIL
FIRE SERVICE
DCDA CONNECTION

City of Wenatchee

REVISIONS	DATE	INITIAL
	02/20	CAW
	01/22	AJS

SCALE: AS SHOWN	DRAWN RDH	DATE DRAWN 3/23/2015	DESIGNED DMN
APPROVED BY	DATE APPROVED	CHECKED DMN	

STANDARD SPECIFICATIONS
6-02 CONCRETE STRUCTURES
7-09 WATER MAINS
7-12 VALVES FOR WATER MAINS
7-15 SERVICE CONNECTIONS

DETAIL NO.
W-200A







NOTES:

1. SIGN TO SAY "SPRINKLER CONNECTION" AND "BLDG. A" (OR WHICHEVER BUILDING IS IDENTIFIED).
2. FIRE DEPARTMENT CONNECTION (FDC) PIPE TO BE PAINTED RUSTOLEUM RED.
3. SIZE OF SIGN TO FIT REQUIRED INFORMATION 3.00" BLOCK LETTERS WHITE ON RED BACKGROUND ON 0.080" RUST FREE ALUMINUM BASE OR BETTER.

STANDARD DETAIL
FIRE SERVICE
STANDALONE FDC

City of Wenatchee

REVISIONS	
DATE	INITIAL
01/22	AJS

SCALE: AS SHOWN	DRAWN: CAW	DATE DRAWN: 2/24/2020
DESIGNED: DMN	CHECKED: DMN	DATE APPROVED:
APPROVED BY:		

STANDARD SPECIFICATIONS
6-02 CONCRETE STRUCTURES
7-09 WATER MAINS
7-12 VALVES FOR WATER MAINS
7-15 SERVICE CONNECTIONS

DETAIL NO.
W-200B

NOTES:

1. TYPICAL LOCATION IS AT OR NEAR THE PROPERTY LINE, AT BACK OF WATER METER CHAMBER.
2. COVER SHALL NOT EXTEND MORE THAN 2" ABOVE GRADE WHEN VAULT IS NOT IN TRAFFIC AREA.
3. SLOPE PAVEMENT AWAY FROM COVER.
4. VAULT LID SHALL BE OF ADEQUATE HEIGHT TO PROVIDE MIN. 6" CLEARANCE TO O, S & Y VALUE WHEN VALVE IS FULLY OPEN.
5. VAULTS SHAL BE AS MANUFACTURED BY UTILITY VAULT OR APPROVED EQUAL AND SHALL BE STRUCTURALLY DESIGNED FOR THE PROPOSED INSTALLATION.
6. BACK–FLOW VALVE AND ASSEMBLY MUST APPEAR ON CURRENT DEPT. OF HEALTH'S APPROVED VALVE LISTING.
7. RESTRAIN CHECK DETECTOR WITH MEGA–LUGS. RESTRAINED JOINT PIPE, OR SHACKLE RODS BACK TO WATER MAIN AS REQUIRED.
8. BOTTOMLESS VAULTS MUST PROVIDE CONCRETE SUPPORT FOUNDATIONS FOR PIPE SUPPORTS.
9. ASSEMBLY SHALL BE MAINTAINED BY OWNER WITH A TEST DONE UPON INSTALLATION AND ANNUALLY THEREAFTER BY A CERTIFIED BACK–FLOW ASSEMBLY TESTER (BAT.) A COPY OF EACH ANNUAL TEST REPORT MUST BE SENT TO THE CITY OF WENATCHEE.
10. WATER SERVICE SHALL NOT BE PLACED IN SERVICE UNTIL AFTER DOUBLE CHECK DETECTOR ASSEMBLY IS INSPECTED. TESTED AND APPROVED BY CITY REPRESENTATIVE.
11. ACCOUNT FOR THERMAL EXPANSION WITHIN THE PREMISES.
12. AN ALTERNATE LOCATION MAY BE ALLOWED BY THE WATER PURVEYOR.



PLAN



SECTION

STANDARD DETAIL
DOUBLE CHECK VALVE
PREMISES ISOLATION

City of Wenatchee

REVISIONS	DATE	INITIAL
	8/4/2020	DMN
	01/01/2022	AJS

SCALE: AS SHOWN	DRAWN RDH	DATE DRAWN 3/23/2015	DATE APPROVED
DESIGNED DMN	APPROVED BY	CHECKED DMN	

STANDARD SPECIFICATIONS
6–02 CONCRETE STRUCTURES
7–09 WATER MAINS
7–12 VALVES FOR WATER MAINS
7–15 SERVICE CONNECTIONS

DETAIL NO.
W–210

PAGE
1 OF 1



PLAN



SECTION

REDUCED PRESSURE BACKFLOW ASSEMBLIES RPBA's & RDDA's

NOTES:

1. ASSEMBLY SHALL BE MAINTAINED BY OWNER, TESTING IS REQUIRED BY A CERTIFIED BACKFLOW ASSEMBLY TESTER (BAT) AFTER INSTALLATION, THEN ANNUALLY THEREAFTER. A COPY OF THE TEST REPORT SHALL BE SENT TO THE CITY OF WENATCHEE.
2. WATER MAIN SHALL NOT BE PLACED IN SERVICE UNTIL AFTER REDUCED PRESSURE BACKFLOW ASSEMBLY IS INSPECTED AND APPROVED BY THE CITY OF WENATCHEE.
3. RESTRAIN ASSEMBLY WITH, MEGA-LUGS, RESTRAINED JOINT PIPE OR SHACKLE RODS BACK TO WATER MAIN AS REQUIRED.
4. SEE CURRENT ADDTION OF AWWA CROSS CONNECTION CONTROL MANUAL FOR ADDITIONAL DETAILS.

STANDARD DETAIL
HOT BOX ENCLOSURE
BACK FLOW ASSEMBLY

City of Wenatchee

REVISIONS	
DATE	01/22
INITIAL	AJS

SCALE: AS SHOWN	DESIGNED	DRAWN	CHECKED
APPROVED BY	DATE DRAWN	DATE APPROVED	STANDARD SPECIFICATIONS

DETAIL NO.
W-230

PAGE
1 OF 1





SECTION



SECTION A-A'





TOUCH READ POCKET DETAIL

DROP LIFT HANDLE





NOTES:

1. MATERIALS SHALL BE SUBMITTED TO THE CITY FOR APPROVAL PRIOR TO INSTALLATION.
2. USE CITY SIDEWALK DETAIL FOR SIDEWALK SURFACING OVER WATER METER CHAMBERS.
3. LOCATE WATER METER CHAMBER UNDER SIDEWALK, SET WATER METER CHAMBER LID FLUSH WITH FINAL SIDEWALK GRADE. WATER METER CHAMBER SHALL BE SET AT A DEPTH TO INCLUDE AT LEAST ONE RISER AND A MAXIMUUM DEPTH OF 4 INCH RISER.
4. WATER CHAMBER CAST IRON FRAME SHALL HAVE A DEPRESSION FOR PRE–APPROVED "FASTENAL 1/4" X 2 1/2" DRIVE ANCHORS PART NUMBER 50608' OR AS APPROVED BY THE CITY ENGINEER.
5. SERVICE TO PROPERTY SHALL BE IN A CASING. THE CASING SHALL BE A MINIMUM DIAMETER OF 2 INCH PVC PIPE, OR 50% GREATER THAN THE SERVICE PIPE WHICHEVER IS LARGER. THE CASING PIPE SALL BE GROUTED FLUSH WITH INSIDE EDGE OF CHAMBER AND EXTENDED TO WITHIN 1 FOOT OF THE PROPERTY LINE OR UTILITY EASEMENT LINE.

STANDARD DETAIL
WATER BOX CHAMBER
WATER METER SERVICES

City of Wenatchee

REVISIONS	DATE	INITIAL
	04/26/2017	DMN
	05/16/2017	DMN
	01/01/2022	AJS

SCALE: AS SHOWN	DATE DRAWN 3/06/2017	DATE APPROVED	STANDARD SPECIFICATIONS 7-09 WATER MAINS 9-30.6 WATER SERVICE CONNECTIONS
DESIGNED	DRAWN MYW	CHECKED DMN	
APPROVED BY			

DETAIL NO.
W–250A

PAGE
1 of 4



PLAN VIEW

ALL CONNECTIONS TO THE DOMESTIC SERVICE MUST BE MADE 3 FEET FROM THE METER CHAMBER. CONTACT CITY OF WENATCHEE WATER DEPARTMENT FOR TURNING OFF/ON WATER INSIDE THE WATER METER CHAMBER. THE CITY OF WENATCHEE STRICTLY PROHIBITS ANYONE FROM ENTERING WATER CHAMBER OR SHUTTING WATER SERVICE OFF WITHIN METER CHAMBER.



SECTION VIEW

NOTES:

1. MATERIALS SHALL BE SUBMITTED FOR CITY APPROVAL PRIOR TO INSTALLATION.
2. MATERIAL SHALL BE NON–LEAD, SUPPLIERS ARE TYPICALLY: FORD, MEULLER, AND AY MCDONALD.
3. WATCH BALL VALVE SIZE TO CTS POLY, MINIMUM PIPE DIAMETER IS 1 $\frac{1}{2}$ INCH FOR ALL SINGLE SERVICES FROM WATER MAIN.
4. DOWNSTREAM WATER SERVICE PIPE DIAMETER SHALL BE THE SAME AS THE WATER METER FOR TEN (10) FEET.
5. BALL VALVE'S COMPRESSION COUPLING TO THE CTS PE WATER SERVICE PIPE SHALL HAVE INSERT AND BE A MAXIMUM OF 2–INCHES FROM INSIDE OF CHAMBER.
6. ALL TAPS SHALL BE BY CITY CREWS

WATER SERVICES		
SINGLE METER SIZE IN CHAMBER (INCHES)	SERVICE TO CHAMBER (INCHES)	SERVICE FROM CHAMBER (INCHES)
$\frac{5}{8}$ OR $\frac{3}{4}$	1 $\frac{1}{2}$ *	3/4
1	1 $\frac{1}{2}$ *	1
1 1/2	1 1/2	1 1/2
2	2	2
* 1–INCH MINIMUM AS DETERMINED BY CITY		

STANDARD DETAIL
1 1/2" OR 2" SINGLE METER SERVICE
WATER METER SERVICES

City of Wenatchee

REVISIONS								
DATE	04/26/2017	01/01/2022						
INITIAL	DMN	AJS						

DATE DRAWN: 3/06/2017
CHECKED: DMN
DATE APPROVED:
SCALE: AS SHOWN
DRAWN: MYW
DESIGNED:
APPROVED BY:
STANDARD SPECIFICATIONS
7–09 WATER MAINS
9–30.6 WATER SERVICE CONNECTIONS

DETAIL NO.
W–250B



PLAN VIEW

ALL CONNECTIONS TO THE DOMESTIC SERVICE MUST BE MADE 3 FEET FROM THE METER CHAMBER. CONTACT CITY OF WENATCHEE WATER DEPARTMENT FOR TURNING OFF/ON WATER INSIDE THE WATER METER CHAMBER. THE CITY OF WENATCHEE STRICTLY PROHIBITS ANYONE FROM ENTERING WATER CHAMBER OR SHUTTING WATER SERVICE OFF WITHIN METER CHAMBER.



SECTION VIEW

NOTES:

1. MATERIALS SHALL BE SUBMITTED FOR CITY APPROVAL PRIOR TO INSTALLATION.
2. MATERIAL SHALL BE NON–LEAD, SUPPLIERS ARE TYPICALLY: FORD, MEULLER, AND AY MCDONALD.
3. MATCH BALL VALVE SIZE TO CTS POLY, 1–½ INCH BY 1–INCH U–BRANCH SET 12–INCH ON CENTER CONNECTED TO 1 ½ INCH BALL VALVE NEAR CHAMBER WALL AND WITH 1–INCH BALL VALVES ON EACH BRANCH.
4. DOWNSTREAM WATER SERVICE PIPE DIAMETER SHALL BE THE SAME AS THE WATER METER FOR TEN (10) FEET.
5. 1 ½ INCH BALL VALVE COMPRESSION COUPLING TO THE CTS PE SERVICE PIPE SHALL BE A MAXIMUM OF 2–INCHES FROM SIDE OF CHAMBER WALL.
6. ALL TAPS SHALL BE BY CITY CREWS

STANDARD DETAIL

2 1" SPLIT FROM 1 1/2" DOUBLE METER SERVICE

WATER METER SERVICES

City of Wenatchee

REVISIONS		
DATE	04/26/2017	01/01/2022
INITIAL	DMN	AJS

DATE DRAWN 3/06/2017	CHECKED DMN	DATE APPROVED	STANDARD SPECIFICATIONS 7–09 WATER MAINS 9–30.6 WATER SERVICE CONNECTIONS
SCALE: AS SHOWN	DRAWN MYW	APPROVED BY	
	DESIGNED		

DETAIL NO.
W–250C



NOTE: RJ IS A RESTRAINED JOINT

WATER PIPING AND VAULT
N.T.S.

NOTES:
1. LADDERS SHALL BE ALUMINUM.
2. LADDER MUST MEET CONSTRUCTION REQUIREMENTS OF ANSI A14.3



LADDER DETAIL
N.T.S.



WATER PIPING AND VAULT
N.T.S.

DOUBLE CHECK VAULT
N.T.S.

NOTES:

1. MATERIALS SHALL BE SUBMITTED FOR CITY APPROVAL PRIOR TO INSTALLATION.
2. MATERIALS SHALL BE NON–LEAD.
3. MATCH BALL VALVE SIZE TO CTS POLY.
4. BALL VALVE COMPRESSION COUPLING TO THE CTS PE WATER SERVICE PIPE SHALL HAVE INSERT AND BE A MAXIMUM OF 2 INCHES FROM INSIDE CHAMBER WALL.
5. DOWNSTREAM WATER SERVICE PIPE DIAMETER SHALL BE THE SAME AS THE WATER METER FOR 3 FEET.
6. ALL TAPS SHALL BE BY CITY CREWS.
7. WATER METER TO BE LOCATED AT BACK OF WALK. SET WATER METER CHAMBER LID FLUSH WITH FINAL SIDEWALK GRADE.
8. EASEMENTS REQUIRED WHEN OUTSIDE RIGHT–OF–WAY.

STANDARD DETAIL
3", 4", AND 6" WATER METER CHAMBER

City of Wenatchee

REVISIONS	
DATE	INITIAL
01/01/2022	AJS

DATE DRAWN 01/28/21	CHECKED	DATE APPROVED	STANDARD SPECIFICATIONS
SCALE: AS SHOWN	DRAWN CAW		
	DESIGNED	APPROVED BY	

DETAIL NO.
W–250D

PAGE
4 OF 4







PIPE SIZE	DIMENSIONS (INCHES)				
	A	B	C	D	E
4"	2.4	4.8	17	13	14.6
6"	3.5	6.9	18	14	14.5
8"	4.5	9.1	19	15	14.5
10"	5.6	11.1	20	16	14.4
12"	6.6	13.2	21	17	14.4
14"	7.7	15.3	22	18	14.3
16"	8.7	17.4	23	19	14.3
18"	9.8	19.5	24	20	14.2

SLOPES > 20% – PROVIDE CONCRETE SLOPE ANCHORS (20' TO 25' ON CENTER.)

STANDARD DETAIL CONCRETE SLOPE ANCHOR

City of Wenatchee

REVISIONS
DATE: 01/01/2022
INITIAL: AJS

DATE DRAWN: 11/04/2020
CHECKED
DATE APPROVED
STANDARD SPECIFICATIONS

SCALE: AS SHOWN
DESIGNED
DRAWN: CAW
APPROVED BY

DETAIL NO.
W–310

PAGE
1 OF 1



ALL PIPE AND FITTINGS SHOWN TO BE GALVANIZED STEEL (WRAPPED), UNLESS OTHERWISE NOTED.

NOTES:

1. WATER METER LIDS SHALL BE "IFCO":
   NO. 2019 TO BE USED IN DRIVEWAYS,
   NO. 2020 WITH DROP HANDLES TO BE USED IN SIDEWALK AREAS
2. AIR VALVE ASSEMBLY SHALL BE INSTALLED AT HIGHEST POINT OF LINE.
3. REBAR STAKE TO SUPPORT VALVE. TWO MAY BE NEEDED.

SOFT SEAT COMBINATION AIR RELEASE/VACUUM VALVE (THREADED), SIZE AS REQUIRED BY CITY. APCO #143C OR 145C, OR VAL-MATIC MODEL 201.C OR 202.C, NO SUBSTITUTIONS.

COMBINATION AIR VALVE
N.T.S.

STANDARD DETAIL
COMBINATION AIR VALVE

City of Wenatchee

REVISIONS	DATE	INITIAL
	12/21/2020	CAW
	01/01/2022	AJS

SCALE: AS SHOWN	DESIGNED	DRAWN: RLK	APPROVED BY
DATE DRAWN: 08/03/2006	CHECKED: SK	DATE APPROVED	STANDARD SPECIFICATIONS

DETAIL NO.
W-400

PAGE
1 OF 1